



## EARLY POWER INSPECTION/TEMPORARY UNDER GROUND (T.U.G.)

### OVERHEAD SERVICE

Weatherhead height	A 230.24
Riser (mast) size	Chapt. 9 Annex C (tables)
Riser (mast) support	A 230.28
Electrical equipment secured	A 110.13, 312.2, 314.23
Grounding conductor size	T. 250.66
Grounding electrode (ufer or alternative)	A 250.50
Equipment grounding conductor	T 250.122
Bonding jumpers (size and connection)	A 250.28

### UNDERGROUND SERVICE

(service laterals NOT installed by the power utility must comply with NEC 300.5(d))

Size of raceway	Chapt. 9 Annex C (tables)
Electrical equipment secured	A 110.13
Grounding conductor size	T 250.66
Grounding electrode (ufer or alternative)	A 250.50
Equipment grounding conductor	T 250.122
Bonding jumpers (size and connection)	A 250.28

Main service disconnect (size)	A 230.79, 314.23
No more than 6 disconnects group w/o a main disconnect	A 230.71, 230.72
Termination of conductors (lugs, clamps and/or connectors tight)	A 110.14
Terminal for more than one conductor and terminals to connect aluminum SHALL be identified	A 110.14A

Equipment, devices and fixtures installed or safely capped.  
Building is weather tight.